



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

April 19, 2021

To Whom It May Concern:

FL-25575

Equivalency of Standards

ANSI/WMA 100-2016


The products referenced in this Product Approval have been tested in accordance with ANSI/WMA 100-2016. It has been determined by Lyndon F. Schmidt, P.E. and RW Building Consultants, Inc. that ANSI/WMA 100-2016 is equivalent to ANSI/WMA 100-2018, which is the reference standard and year that has been adopted by the 7th Edition (2020) Florida Building Code - Residential.

ASTM E 1886-05 Equivalent to ASTM E 1886-13a

The products referenced in this Product Approval have been tested in accordance with ASTM E 1886-05. It has been determined by Lyndon F. Schmidt, P.E. and RW Building Consultants, Inc. that ASTM E 1886-05 is equivalent to ASTM E 1886-13a, which is the reference standard and year that has been adopted by the 7th Edition (2020) Florida Building Code.

ASTM E 1996-09 Equivalent to ASTM E 1996-14a

The products referenced in this Product Approval have been tested in accordance with ASTM E 1996-09. It has been determined by Lyndon F. Schmidt, P.E. and RW Building Consultants, Inc. that ASTM E 1996-09 is equivalent to ASTM E 1996-14a, which is the reference standard and year that has been adopted by the 7th Edition (2020) Florida Building Code.


4.19.21

Lyndon F. Schmidt, P.E.
FL No. 43409
Registry License No. 9813

