

**Product Evaluation Report**

**Report No.:** FL-47284.9

**Date:** July 2, 2025

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Trinity Glass International 33615 1st Way S Federal Way, Washington 98446	"Direct Glaze" Single Fiberglass Door Inswing / Outswing "Impact"

**Scope:** This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. for Trinity Glass International based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

**Limitations:**

- This product anchoring drawing has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) including the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in the "HVHZ", this product complies with Section 1626 of the Florida Building Code and does not require an impact resistant covering.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-47284.9 require further engineering analysis by a licensed engineer or registered architect
- This product meets the water infiltration requirements for the "HVHZ".
- See drawing FL-47284.9 for size and design pressure limitations.

**Supporting Documents:**

- |  |  |   |  |
|--|--|---|--|
| <p>1. <b>Test Report No.</b><br/>TEL 04253960<br/>TEL 01370206A,B,C<br/>TEL 01370206D<br/>TEL 01370210A,B,C<br/>TEL 01370210D</p>  | <p><b>Test Standard</b><br/>TAS 201, 202, &amp; 203-94<br/>ASTM D 1929-96, 635-03, 2843-99<br/>ASTM G 155-05a, D 638-03<br/>ASTM D 1929-96, 635-03, 2843-99<br/>ASTM G 155-05a, D 638-03</p> | <p><b>Testing Laboratory</b><br/>Testing Evaluation Lab.,Inc.<br/>Testing Evaluation Lab.,Inc.<br/>Testing Evaluation Lab.,Inc.<br/>Testing Evaluation Lab.,Inc.<br/>Testing Evaluation Lab.,Inc.</p> | <p><b>Signed by</b><br/>William B. Shelton, P.E.<br/>V. K. Wright<br/>V. K. Wright<br/>V. K. Wright<br/>V. K. Wright</p> |
| <p>2. <b>Drawing No.</b><br/>No. FL-47284.9</p>  | <p><b>Prepared by</b><br/>RW Building Consultants, Inc. (#9813)</p>  |   | <p><b>Signed &amp; Sealed by</b><br/>Lyndon F. Schmidt, P.E.</p>   |
| <p>3. <b>Miami-Dade NOA No.</b><br/>23-0713.18</p>   | <p><b>Materials Testing</b><br/>Saflex PVB Interlayer (Eastman Chemical Company)</p>   |   |  |
| <p>4. <b>Calculations</b><br/>Anchoring<br/>ASTM E 1300 Glass Load</p>   | <p><b>Prepared by</b><br/>RW Building Consultants, Inc. (#9813)<br/>RW Building Consultants, Inc. (#9813)</p>  |   | <p><b>Signed &amp; Sealed by</b><br/>Lyndon F. Schmidt, P.E.</p>   |
| <p>5. <b>Quality Assurance</b><br/>Certificate of Participation issued by National Accreditation and Management Institute, certifying that Trinity Glass International is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.</p> |  |   |  |

Digitally signed by  
Lyndon F Schmidt  
Date: 2025.07.02  
11:15:51 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409  
This item has been digitally signed and sealed by L. F. Schmidt on 7-2-25.  
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.  
**THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA**